CONTROL VALVE SERIES 2000 SERIES 2003

POLNACORP



www.polnacorp.ru

Working: control

2V – NC - Normally closed (air open straight way) 2V – NO – Normally open (air close straight way) 3V – Diverting/Mixing

Size

Ň

DN 15 - DN 100 (1)

Rating

PN 16 - PN 40

Body material

Nodular cast iron GS 400-12 (epoxy varnish) PN 16 Carbon steel ASTM A 216 WCB (epoxy varnish) PN 40 Stainless steel AISI 316 PN 40

Seat

Stainless steel AISI 316L Stainless steel AISI 316L stellited

End connections (2)

Flanges PN 16, PN 40

- Projection (RF) UNI 2229

Bonnet

Standard in ASTM A105, AISI 420, AISI 316

- Standard
- Finned and extended
- With bellows
- Estended for cryogenic use

Plug (3)

Equipercentual, linear, V-port, microflow, double guid. - AISI 316L (metallic seal) - AISI 316L (metallic seal), stellited

Self-adjusting packing box

"V" rings in PTFE + graphite ring "V" rings in PTFE + reinforced graphite rings "V" rings in pure PTFE

Castle

Nodular cast iron GS 400-12 (epoxy varnish)

Servocontrol

With pneumatic action (max 2,5 bar) direct and reverse in stamped plate FE (epoxy varnish) Size: S.200, S.275, S.340, S.430 Standard spring range: 3-15 psi, 6-18 psi, 6-30 psi Current equipment: Travel indicator Accessories: handwheel for manual control, electropositioner pneumatic positioner, endstroke microswithches, proximity sensors, reducing filter, converter.

Differential pressure Δp

See table "Technical Specifications"

Seal class

According to UNI EN 1349 - Metallic –class IV - class VI

Employment limits

Body in nodular cast iron: min temp. -5° C, max temp. 200° C - max steam 12 bar, water at room temp. max 16 bar. Body in WCB steel: min temp. -5° C, max temp. 350° C - max steam 12 bar, overheated water max 35 bar. Body in AISI 316: min temp. -200° C, max temp. 350° C

Employment fields

The valves serie 2000/2003, can control different kinds of fluid:

steam, overheated water, diathermic oil, no-explosive gas, corrosive fluids, cryogenic gas, etc. For this reason they can be employed in several sectors as: textile dyeing and finishing plants, chemical plants, water-treating, alimentary, general industrial plants.

Special executions on request.

Notes

- (1) Greater sizes or reduced Cv on request.
- (2) Other end connections on request.
- (3) Other seals on request.



PNEUMATIC CONTROL VALVE - serie 2000

The control valves serie **2000** have two way globe body with screwed single seat and lower bottom for inspection and plug replacement (inversed version). The plug has double guide and the self-adjusting packing box does not need maintenance. They are particularly indicated for regulation in medium heavy plants.

The total dimension of the valve is calculated by inserting the servocontrol size, chosen according to the pressure of the fluid to control.





SERVOCONTROL

| DN | 15/25 | 25/50 | 45/65 | 50/100 | | | |
|-------|-------|-------|-------|--------|--|--|--|
| D | 200 | 275 | 340 | 430 | | | |
| E | 88 | 88 | 122 | 143 | | | |
| G gas | 1/8″ | 1/4" | | | | | |

HANDWHEEL (option)

| D | 200 | 275 | 340 | 430 |
|---|-----|-----|-----|-----|
| F | | 162 | | |
| V | | 225 | | |

TABLE VALVES DIMENSIONS

| DN | Α | В | С | Н | I | L | Holes |
|-----|-----|-----|-----|------|------|-----|-------|
| 15 | 150 | 96 | 297 | 95 | 65 | 14 | 4 |
| 20 | 150 | 96 | 297 | 105 | 75 | 14 | 4 |
| 25 | 160 | 156 | 297 | 115 | 85 | 14 | 4 |
| 32 | 180 | 156 | 297 | 140 | 100 | 18 | 4 |
| 45 | 200 | 156 | 297 | 150 | 110 | 18 | 4 |
| 50 | 230 | 166 | 297 | 165 | 125 | 18 | 4 |
| 65 | 200 | 210 | 222 | 105 | 145 | 10 | 4 |
| 60 | 290 | 219 | 222 | 165 | 145 | 18 | 8* |
| 80 | 310 | 220 | 350 | 220 | 160 | 18 | 8 |
| 100 | 250 | 240 | 250 | 200 | 180 | 18 | 0 |
| 100 | 350 | 240 | 350 | 235* | 190* | 22* | ð |

 \mathbb{A}

PNEUMATIC CONTROL VALVE - serie 2003

The control valves serie **2003** have globe body with screwed seat and third way with welded seat. The V-port plug has double guide and the self-adjusting packing box does not need maintenance. They are particularly indicated for regulation in medium heavy plants.

The total dimension of the valve is calculated by inserting the servocontrol size, chosen according to the pressure of the fluid to control.





SERVOCONTROL

| DN | 25/50 | 45/65 | 50/100 | | | | | | |
|-------|-------|-------|--------|--|--|--|--|--|--|
| D | 275 | 340 | 430 | | | | | | |
| E | 88 | 122 | 143 | | | | | | |
| G gas | 1/4" | | | | | | | | |

HANDWHEEL (option)

| D | 275 | 340 | 430 |
|---|-----|-----|-----|
| F | 1: | 162 | |
| V | 12 | 225 | |



| DN | А | В | С | Н | I | L | Holes |
|-----|-----|-----|-----|---------|---------|-----|-------|
| 25 | 160 | 156 | 297 | 115 | 85 | 14 | 4 |
| 32 | 180 | 156 | 297 | 140 100 | | 18 | 4 |
| 40 | 200 | 156 | 297 | 150 | 150 110 | | 4 |
| 50 | 230 | 166 | 297 | 165 | 125 | 18 | 4 |
| 65 | 200 | 210 | 222 | 105 | 145 | 10 | 4 |
| 60 | 290 | 219 | 222 | 165 | 145 | 18 | 8* |
| 80 | 350 | 220 | 333 | 200 | 160 | 18 | 8 |
| 100 | 350 | 240 | 250 | 220 | 180 | 18 | 0 |
| 100 | | | 350 | 235* | 190* | 22* | ð |

(*) Flanges PN 40 - N.B. Measures are in mm.



MIXING



PLUG SPECIFICATIONS



LINEAR PLUG.

With this type of plug you obtain linearity between stroke and flow rate which results proportional to the opening degree of the valve. It is utilized when there are no important variations in working differential pressure, or in processes with limited flow rate variations.



With this plug there is a constant percentage of flow increase for an equal increase in the opening stroke; under the same differential pressure, a stroke increase of 10% usually corresponds to a flow increase equal to 50% of the valve preceding the variation. The result is that the valve delivers the most of the flow rate in its last opening fraction. It is utilized when there are notable variations in flow rate or in differential pressure.



MICROFLOW PLUG.

For this type of plug we have three profiles: linear pin, single spline and doublespline equipercentage. Rate coefficients from CV 0,1 to CV 2, for a fine and precise regulation.

BONNET SPECIFICATIONS



STANDARD BONNET.

Bonnet for the regulation of fluids with temperatures no higher than 200 °C. The packing box is composed of "V" rings in PTFE (also available in double seal version), or of "V" rings in PTFE + graphite rings.

EXTENDED AND FINNED BONNET.

Purposely studied bonnet for use with fluids with temperatures up to about 300 °C (diathermic oil and overheated water). The bonnet is extended and has fins to space the packing box from the body valve and allow a better loss of heat. This device permits the use of a standard packing box composed of "V" rings in PTFE + graphite rings.



EXTENDED BONNET FOR CRYOGENIC USE .

Studied bonnet for applications with fluids with extremely low temperatures, up to -196 °C which liquefy gas as nitrogen, oxygen, argon, helium etc. The isolation extension for low temperatures avoids the heat exchange inside the valve and protects the security packing box and the servocontrol from the icing. There are two versions of extensions in AISI 316 for use with cryogenic fluids:

• Extended bonnet for -60°C.

• Extended bonnet for -200°C (minimum working temperature -196°C).

The packing box is composed of "V" rings in PTFE.



The characteristic curve of this type of plug finds its rightful place between a linear and equipercentage curve with a sensible tendency to this last one. It is utilized principally for the three-way version since its extended shape assures a guided stroke without vibrations.



CE .



BONNET WITH BELLOWS.

Purposely studied bonnet which can be used when you need a perfect seal of the valve, for example in presence of dangerous fluids. This bonnet has a metallic seal bellows with double wall (thickness 0,2 mm) in stainless steel AISI 316. The maximum application temperature is 350 °C.

The packing box is composed of "V" rings in PTFE and "V" rings in PTFE + graphite rings.

TECNICAL SPECIFICATION

 \aleph

| | MAX DIFFERENTIAL PRESSURES AT CLOSED VALVE (bar) - AIR TO CLOSEOPEN ACTION | | | | | | | | | | | | | | |
|-----|--|-----|------|----------|----------|----------|----------|----------|-----------|------------|----------|----------|----------|----------|----------|
| | | | | | S200 | | | S275 | | | S340 | | | S430 | |
| | | | | | | | | | Imput p | oressure | | | | | |
| | â | | | 1 | .4 | 2.5 | 1 | .4 | 2.5 | 1. | .4 | 2.5 | 1. | .4 | 2.5 |
| DN | rro! | Cv | Kv | | | | | Sp | ring rang | e (Bar & P | si) | | | | |
| | ſS | | | 0.2 | 0.4 | 0.4 | 0.2 | 0.4 | 0.4 | 0.2 | 0.4 | 0.4 | 0.2 | 0.4 | 0.4 |
| | | | | 1 | 1.2 | 2.1 | 1 | 1.2 | 2.1 | 1 | 1.2 | 2.1 | 1 | 1.2 | 2.1 |
| | | | | 3-15 psi | 6-18 psi | 6-30 psi | 3-15 psi | 6-18 psi | 6-30 psi | 3-15 psi | 6-18 psi | 6-30 psi | 3-15 psi | 6-18 psi | 6-30 psi |
| 15 | | 4 | 3.5 | 5.8 | 13.8 | 22 | 15.4 | 33.1 | 40 | | | | | | |
| | | 2.5 | 2.1 | 24.1 | 40 | 40 | 20.2 | 24.6 | 40 | | | | | | |
| | | 7 | 6 | 5.8 | 13.8 | 18 | 15.4 | 33.1 | 40 | | | | | | |
| 20 | | 4 | 3.5 | 5.8 | 13.8 | 22 | 15.4 | 33.1 | 40 | | | | | | |
| | | 2.5 | 2.1 | 24.1 | 40 | 40 | 20.2 | 24.6 | 40 | | | | | | |
| | | 12 | 10 | 3.9 | 9.5 | 14 | 10.6 | 23 | 40 | | | | | | |
| 25 | | 7 | 6 | 5.8 | 13.8 | 18 | 15.4 | 33.1 | 40 | | | | | | |
| 25 | | 4 | 3.5 | 5.8 | 13.8 | 22 | 15.4 | 33.1 | 40 | | | | | | |
| | | 2.5 | 2.1 | 24.1 | 40 | 40 | 20.2 | 24.6 | 40 | | | | | | |
| | | 18 | 15.5 | | | | 5.9 | 12.9 | 26.9 | 10 | 21.1 | 30 | | | |
| | | 12 | 10 | | | | 10.6 | 23 | 40 | 17.9 | 37.5 | 40 | | | |
| 32 | | 7 | 6 | | | | 15.4 | 33.1 | 40 | 25.8 | 40 | 40 | | | |
| | 20 | 4 | 3.5 | | | | 15.4 | 33.1 | 40 | 25.8 | 40 | 40 | | | |
| | 20 | 2.5 | 2.1 | | | | 20.2 | 24.6 | 40 | 40 | 40 | 40 | | | |
| | | 28 | 24 | | | | 4.1 | 9.1 | 19.1 | 7 | 15 | 25 | | | |
| | | 18 | 15.5 | | | | 5.9 | 12.9 | 26.9 | 10 | 21.1 | 30 | | | |
| 40 | | 12 | 10 | | | | 10.6 | 23 | 40 | 17.9 | 37.5 | 40 | | | |
| 40 | | 7 | 6 | | | | 15.4 | 33.1 | 40 | 25.8 | 40 | 40 | | | |
| | | 4 | 3.5 | | | | 15.4 | 33.1 | 40 | 25.8 | 40 | 40 | | | |
| | | 2.5 | 2.1 | | | | 20.2 | 24.6 | 40 | 40 | 40 | 40 | | | |
| | | 48 | 41 | | | | 2.3 | 5.2 | 11 | 4 | 8.6 | 14 | 7.1 | 15 | 22 |
| | | 28 | 24 | | | | 4.1 | 9.1 | 14.3 | 7 | 15 | 25 | 12.5 | 22 | 30 |
| | | 18 | 15.5 | | | | 5.9 | 12.9 | 19.1 | 10 | 21.1 | 30 | 17.7 | 36.6 | 40 |
| 50 | | 12 | 10 | | | | 10.6 | 23 | 26.9 | 17.9 | 37.5 | 40 | 31.5 | 40 | 40 |
| | | 7 | 6 | | | | 15.4 | 33.1 | 40 | 25.8 | 40 | 40 | 40 | 40 | 40 |
| | | 4 | 3.5 | | | | 15.4 | 33.1 | 40 | 25.8 | 40 | 40 | 40 | 40 | 40 |
| | | 72 | 61.5 | | | | | | | 2.4 | 5.2 | 9 | 4.3 | 9.1 | 12 |
| | | 48 | 41 | | | | | | | 4 | 8.6 | 14 | 7.1 | 15 | 20 |
| 65 | | 28 | 24 | | | | | | | 7 | 15 | 25 | 12.5 | 22 | 30 |
| | 20 | 18 | 15.5 | | | | | | | 10 | 21.1 | 30 | 17.7 | 36.6 | 40 |
| | 30 | 105 | 90 | | | | | | | 1.9 | 4.2 | 5.5 | 3.5 | 7.4 | 9 |
| 0.0 | | 72 | 61.5 | | | | | | | 2.4 | 5.2 | 9 | 4.3 | 9.1 | 12 |
| 80 | 80 | 48 | 41 | | | | | | | 4 | 8.6 | 14 | 7.1 | 15 | 20 |
| | | 28 | 24 | | | | | | | 7 | 15 | 25 | 12.5 | 22 | 30 |
| | | 160 | 136 | | | | | | | 1 | 2.3 | 3.6 | 1.9 | 4 | 5 |
| | | 105 | 90 | | | | | | | 1.9 | 4.2 | 5.5 | 3.5 | 7.4 | 9 |
| 100 | 35 | 72 | 61.5 | | | | | | | 2.4 | 5.2 | 9 | 4.3 | 9.1 | 12 |
| | | 48 | 41 | | | | | | | 4 | 8.6 | 14 | 7.1 | 15 | 20 |
| | | 28 | 24 | | | | | | | 7 | 15 | 25 | 12.5 | 22 | 30 |

= Standard

TECNICAL SPECIFICATION

| MAX DIFFERENTIAL PRESSURES AT CLOSED VALVE (bar) - AIR TO CLOSE ACTION | | | | | | | | | | | | | | | | |
|--|-----|-----|------|-------|--------------------|----|------|------|---------|----------|------|------|------|------|------|--|
| | | | | | S200 | | | S275 | | | S340 | | | S430 | | |
| | | | | | | | | | Imput p | oressure | | | | | | |
| | Ш | | | 1.2 | 1.4 | 3 | 1.2 | 1.4 | 3 | 1.2 | 1.4 | 3 | 1.2 | 1.4 | 3 | |
| DN | ROF | Cv | Kv | | Spring range (Bar) | | | | | | | | | | | |
| | S | | | 0.2-1 | | | | | | | | | | | | |
| | | | | | Spring range (Psi) | | | | | | | | | | | |
| | | | | | | | | | 3- | 15 | | | | | | |
| 15 | | 4 | 3.5 | 5.8 | 13.8 | 40 | 15.4 | 33.1 | 40 | | | | | | | |
| 15 | | 2.5 | 2.1 | 24.1 | 40 | 40 | 40 | 40 | 40 | | | | | | | |
| | | 7 | 6 | 5.8 | 13.8 | 40 | 15.4 | 33.1 | 40 | | | | | | | |
| 20 | | 4 | 3.5 | 5.8 | 13.8 | 40 | 15.4 | 33.1 | 40 | | | | | | | |
| | | 2.5 | 2.1 | 24.1 | 40 | 40 | 40 | 40 | 40 | | | | | | | |
| | | 12 | 10 | 3.9 | 9.5 | 40 | 10.6 | 23 | 40 | | | | | | | |
| 25 | | 7 | 6 | 5.8 | 13.8 | 40 | 15.4 | 33.1 | 40 | | | | | | | |
| 25 | | 4 | 3.5 | 5.8 | 13.8 | 40 | 15.4 | 33.1 | 40 | | | | | | | |
| | | 2.5 | 2.1 | 24.1 | 40 | 40 | 40 | 40 | 40 | | | | | | | |
| | | 18 | 15.5 | | | | 5.9 | 12.9 | 40 | 10 | 21.1 | 40 | | | | |
| | | 12 | 10 | | | | 10.6 | 23 | 40 | 17.9 | 37.5 | 40 | | | | |
| 32 | | 7 | 6 | | | | 15.4 | 33.1 | 40 | 25.8 | 40 | 40 | | | | |
| | 20 | 4 | 3.5 | | | | 15.4 | 33.1 | 40 | 25.8 | 40 | 40 | | | | |
| | 20 | 2.5 | 2.1 | | | | 40 | 40 | 40 | 40 | 40 | 40 | | | | |
| | | 28 | 24 | | | | 4.1 | 9.1 | 40 | 7 | 15 | 40 | | | | |
| | | 18 | 15.5 | | | | 5.9 | 12.9 | 40 | 10 | 21.1 | 40 | | | | |
| 10 | | 12 | 10 | | | | 10.6 | 23 | 40 | 17.9 | 37.5 | 40 | | | | |
| 40 | | 7 | 6 | | | | 15.4 | 33.1 | 40 | 25.8 | 40 | 40 | | | | |
| | | 4 | 3.5 | | | | 15.4 | 33.1 | 40 | 25.8 | 40 | 40 | | | | |
| | | 2.5 | 2.1 | | | | 40 | 40 | 40 | 40 | 40 | 40 | | | | |
| | | 48 | 41 | | | | 2.3 | 5.2 | 28.4 | 4 | 8.6 | 36,1 | 7.1 | 15 | 40 | |
| | | 28 | 24 | | | | 4.1 | 9.1 | 40 | 7 | 15 | 40 | 12.5 | 22 | 40 | |
| 50 | | 18 | 15.5 | | | | 5.9 | 12.9 | 40 | 10 | 21.1 | 40 | 17.7 | 36.6 | 40 | |
| 50 | | 12 | 10 | | | | 10.3 | 23 | 40 | 17.9 | 37.5 | 40 | 31.5 | 40 | 40 | |
| | | 7 | 6 | | | | 15.4 | 33.1 | 40 | 25.8 | 40 | 40 | 40 | 40 | 40 | |
| | | 4 | 3.5 | | | | 15.4 | 33.1 | 40 | 25.8 | 40 | 40 | 40 | 40 | 40 | |
| | | 72 | 61.5 | | | | | | | 2.3 | 5.1 | 22 | 4.3 | 9 | 40 | |
| 65 | | 48 | 41 | | | | | | | 4 | 8.6 | 36.1 | 7.1 | 15 | 40 | |
| 05 | | 28 | 24 | | | | | | | 7 | 15 | 40 | 12.5 | 26 | 40 | |
| | 30 | 18 | 15.5 | | | | | | | 10 | 21.1 | 40 | 17.7 | 36.6 | 40 | |
| | 50 | 105 | 90 | | | | | | | 1.8 | 4.2 | 18 | 3.4 | 7.4 | 38.6 | |
| 80 | | 72 | 61.5 | | | | | | | 2.3 | 5.1 | 22 | 4.3 | 9 | 40 | |
| 00 | | 48 | 41 | | | | | | | 4 | 8.6 | 36.1 | 7.1 | 15 | 40 | |
| | | 28 | 24 | | | | | | | 7 | 15 | 40 | 12.5 | 26 | 40 | |
| | | 160 | 136 | | | | | | | 1 | 2.2 | 10 | 1.9 | 4 | 21.4 | |
| | | 105 | 90 | | | | | | | 1.8 | 4.2 | 18 | 3.4 | 7.4 | 38.6 | |
| 100 | 35 | 72 | 61.5 | | | | | | | 2.3 | 5.1 | 22 | 4.3 | 9 | 40 | |
| | | 48 | 41 | | | | | | | 4 | 8.6 | 36.1 | 7.1 | 15 | 40 | |
| | | 28 | 24 | | | | | | | 7 | 15 | 40 | 12.5 | 26 | 40 | |

= Standard

 \aleph

VALVE PARTS NOMENCLATURE



| 1 | Membrane disc | 13 | Bottom/Third way |
|----|---------------------|----|-------------------|
| 2 | Membrane | 14 | Flange |
| 3 | Servocontrol spring | 15 | Valve body |
| 4 | Stem guide | 16 | Castle |
| 5 | Regulation nut | 17 | Ring nut |
| 6 | Position indicator | 18 | Packing box nut |
| 7 | Packing box spring | 19 | Stem plug |
| 8 | Packing box | 20 | Data plate |
| 9 | Bonnet | 21 | Stoke plate |
| 10 | Gasket | 22 | Servocontrol stem |
| 11 | Plug | 23 | Lower head |
| 12 | Seat | 24 | Upper head |
| | | | |

ACCESSORIES



ELECTROPNEUMATIC CONVERTER



LIMIT MICROSWITCHES



HANDWHEEL



PNEUMATIC POSITIONER AND REDUCING FILTER



ELECTROPNEUMATIC POSITIONER

WARNING

Before starting the plant the pipes must be cleaned carefully with the fluid pressure at maximum and the valve fully open. It is advisable to place a filter on the valve inlet to prevent foreign objects from entering between the seat and the valve plug. (We recommend to utilize filtered, dry air to feed the pneumatic servocontrol). The best fitting position of the valve is in vertical, and its best working is when the flow direction is opposite to the valve plug (see the arrow on the body valve). After some hours of full working at temperature, check the correct lock of the screws of the body valve. Verify that with valve fitted on the plant a sufficient space is left for removing the servocontrol for maintenance operations. Before removing the servocontrol check that there is no fluid in pressure and at temperature in the plant and set the valve in opening position. In case of a complete dismantling of the servocontrol use proper instruments and proceed with attention to discharge springs tension. **IMPORTANT: do not insert hands, tools or other objects inside the valve body.**



POLNA corp. s.r.o.

Head office:

Oldřichovice 1044 739 61 Třinec Czech Republic tel.: +420 737 238 406 fax: +420 558 338 330 e-mail: info@polnacorp.ru web: www.polnacorp.ru

www.polnacorp.ru